



# City of Eudora Fire Department

## FIRE AND LIFE SAFETY CHECKLIST FOR GROUP, LICENSED, AND REGISTERED CHILD CARE HOMES

NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE/ZIP: \_\_\_\_\_

TELEPHONE: \_\_\_\_/\_\_\_\_/\_\_\_\_

LICENSE NUMBER \_\_\_\_\_

DATE OF LICENSE \_\_\_\_/\_\_\_\_/\_\_\_\_

	MET	NOI	MET	NA
<input type="checkbox"/> Child care provider is in a structure designed and/or used as a one or two family dwelling. Day Care <u>Center</u> requirements <u>must</u> apply if in an apartment, church, commercial building, or other area.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Child care is on the main level and has two remote, compliant exits. (SEE FIRE FACT 023) (Secondary exit may be a compliant rescue/ventilation window or a door leading directly to the outside)	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Child care is in the basement area and has compliant exiting. (SEE FIRE FACT 023) (Secondary exit may be compliant stairs leading to the main level, a compliant rescue/ventilation window, or a door leading directly to the outside)	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Child care is on the second floor and has compliant exiting. (SEE FIRE FACT 023) (Secondary exit may be a compliant stairs leading to the main level, or a rescue/ventilation window or door directly to the outside with stairs leading to the ground Ladders of any type are not acceptable.)	<input type="checkbox"/>		<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Primary or Secondary means of escape does not exit through any hazard area (garage, storage, etc.).	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Every required exit door can be easily opened from the inside at all times when the facility is operating.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Every ESCAPE PATH including all stairways is clear of obstacles and all doors are in proper working condition.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Working smoke detectors are located in every exit pathway, in each sleeping room used for child care, and on each level of the house. Single-station smoke detection hardwired to the electrical system with battery back up or ten year lithium battery detectors shall be required for initial inspection.	<input type="checkbox"/>		<input type="checkbox"/>	
			Install Date of Battery	_____
<input type="checkbox"/> Smoke detectors are tested monthly and records are kept on file for review.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Copy of the current FIRE/LIFE SAFETY AGREEMENT is posted next to license.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Children can open every closet door from the inside at all times.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Written emergency procedures for fire evacuation are provided and practiced monthly.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Monthly fire drills are documented. Drills shall be conducted and evacuation times shall be within 4 minutes. Inspector may ask the operator to demonstrate ability to conduct such a fire drill in his or her presence.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Written emergency procedures for tornadoes are provided and practiced monthly April through September.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Every bathroom door can be unlocked from the outside at all times. The unlocking key or device is readily accessible to the provider.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> All unused electrical outlets in licensed areas have child-resistant protective covers.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> All natural gas, kerosene, wood, propane heaters, etc., are properly vented to the outside of the home.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> A barrier that prevents children from getting too close or burned protects all heating devices.	<input type="checkbox"/>		<input type="checkbox"/>	
<input type="checkbox"/> Fire extinguishers are placed along designated egress, in the kitchen, and other hazard areas as required.	<input type="checkbox"/>		<input type="checkbox"/>	

DATE OF INSPECTION \_\_\_\_/\_\_\_\_/\_\_\_\_ PROVIDER SIGNATURE: \_\_\_\_\_

INSPECTOR/DEPARTMENT SIGNATURE: \_\_\_\_\_ Registered daycare  Licensed daycare  Courtesy Inspection

\*\*\*This is a general checklist compiled by the Kansas State Fire Marshal's Office (KSFMO) in accordance with the Kansas Fire Prevention Code Unless this document has been signed by a KSFMO Inspector it is NOT an official KSFMO document Updated as of 9/1/06 \*\*\*