



8. A fire extinguisher rated at 2-A:10BC (5 lb. ABC extinguisher) is provided and is mounted near an exit so it is easily available for immediate use	Yes	No	N/A
9. The fire extinguisher has been inspected and/or serviced and tagged once within the last 12 months by a person or firm licensed by the Kansas State Fire Marshal. (If the fire extinguisher was purchased new, it does not need to be checked or tagged for 12 months, receipt kept on file for review upon request)	Yes	No	N/A
10. 10 year rated lithium battery powered smoke detectors are installed according to the manufacturer's instructions and Kansas State Fire Marshal's office regulations. Smoke detectors must be installed on every level of the home in all exit pathways leading directly to the outside and in every sleeping/nap room used for the children in the daycare.	Yes	No	N/A
11. Smoke detectors are tested monthly and non lithium battery powered smoke detectors have the batteries changed twice a year and records are kept on file for review upon request.	Yes	No	N/A

12. Fire drill procedures are posted and fire drills are conducted once a month and records of the drills are kept and posted in plain view at the day care.	Yes	No	N/A
13. Written emergency procedures for tornadoes are provided and practiced monthly.	Yes	No	N/A
14. Every bathroom door can be unlocked from the outside at all times. The unlocking key/device is readily accessible to the staff.	Yes	No	N/A
15. All unused electrical outlets (in licensed areas) have child-resistant protective covers.	Yes	No	N/A
16. All natural gas, kerosene, wood, propane heaters, etc. are properly vented to the outside of the home.	Yes	No	N/A
17. All heating devices are protected by a barrier that prevents children from getting close to the heater to avoid burns.	Yes	No	N/A
18. There is no combustible storage within 36 inches of the furnace or hot water heater and both appliances are clean and dust free.	Yes	No	N/A
19. There are no extension cords or multiplug adapters in the day care. (Power strips and surge suppressors are allowed).	Yes	No	N/A
20. There is a working flashlight available for each staff member in the day care.	Yes	No	N/A

(Check One)  <input type="checkbox"/> Disapproved  <input type="checkbox"/> Worksheet information Verified with on-site visit.  <input type="checkbox"/> Complies with local requirements above State minimum.	Fire Inspector Signature	Date:
	Name: <b>Lawrence-Douglas County Fire Medical Department</b>	FDID #: <b>DG101</b>
	Comments:	